

GROUNDWATER INFORMATION SHEET

Dibromochloropropane (DBCP)

Revised: June 2010

The purpose of this groundwater information sheet is to provide general information regarding a specific constituent of concern (COC). The following information, compiled by the staff of the Groundwater Ambient Monitoring and Assessment (GAMA) Program, is pulled from a variety of sources and relates mainly to drinking water. For additional information, the reader is encouraged to consult the references cited at the end of the information sheet.

GENERAL INFORMATION	
Constituent of Concern	Dibromochloropropane (DBCP)
Synonyms	1,2-Dibromo-3-chloropropane, BBC 12, Fumagone, Fumazone, Nemabrom, Nemaforme, Nemaforme, Nemanax, Nemapaz, Nemaset, Nematocide, Nematox, Nemazone, OS1987, OxyDBCP, Gro-Tone Nematode, Durham Nematicide, OS 1897
Chemical Formula	C ₃ H ₅ Br ₂ Cl
CAS No.	96-12-08
Storet No.	38761
Summary	The California Department of Public Health (CDPH) regulates dibromochloropropane (DBCP) as a drinking water contaminant. The California State Maximum Contaminant Level (MCL) for DBCP is 0.2 µg/L. DBCP was used as a soil fumigant in the control of nematodes. The agricultural application of DBCP was banned in the continental United States in 1979. Very small quantities are still used as an intermediate in chemical synthesis. Based on a CDPH data query dated June 2010 using GeoTracker GAMA, 364 active and standby public drinking water wells of 7,689 sampled have had concentrations of DBCP above the MCL of 0.2 µg/L. Most DBCP detections of DBCP above the MCL have occurred in Fresno, Stanislaus, San Joaquin and San Bernardino, counties.

REGULATORY AND WATER QUALITY LEVELS¹		
DBCP		
Type	Agency	Concentration
Federal MCL	US Environmental Protection Agency (US EPA)	0.2 µg/L
Federal Maximum Contaminant Level Goal (MCLG)		Zero
State MCL	CDPH	0.2 µg/L
Detection Limit for Purposes of Reporting (DLR)		0.01 µg/L
Others:	OEHHA US EPA, Region 9	0.0017 µg/L
Public Health Goal (PHG) Tap Water Preliminary Remediation Goal (PRG)		0.0047 µg/L

¹These levels generally relate to drinking water. Other water quality levels may exist. For further information, see *Water Quality Goals* (Marshack, 2008).

SUMMARY OF DETECTIONS IN PUBLIC DRINKING WATER WELLS^{2,3}	
Detection Type	Number of Groundwater Wells
Number of active and standby public drinking water wells with DBCP concentrations > 0.2 µg/L	364 of approximately 7,689 sampled
Top 4 counties with active and standby public drinking water wells with DBCP concentrations > 0.2 µg/L	Fresno (121), Stanislaus (46), San Joaquin (46) and San Bernardino (44),

²Based on CDPH database query dated June 2010 using GeoTracker GAMA.

³In general, drinking water from active and standby wells is treated or blended so consumers are not exposed to water exceeding MCLs. Private domestic wells and wells used by small water systems not regulated by CDPH are not included in these figures.

ANALYTICAL INFORMATION		
Method	Detection Limit	Note
US EPA 504.1, 551.1	0.01 µg/L	CDPH approved for public drinking water systems
US EPA 524.1; 524.2	0.05 µg/L	
Known Limitations to Analytical Methods	<p>Samples are preserved with sodium thiosulfate to avoid possible reactions between residual chlorine and contaminants present in some solvents. Potential for interference with impurities contained in extracting solvents. The US EPA recommends methods 504.1 and 551.1.</p> <p>DBCP can be misidentified as ethylene dibromide. Laboratory confirmation procedures outlined by the US EPA should be strictly adhered to.</p>	
Public Drinking Water Testing Requirements	<p>CDPH established an MCL of 0.2 µg/L for this pesticide in 1989, with associated requirements for quarterly monitoring, compliance determinations, and treatment. In 1992, the US EPA adopted an MCL of 0.2 µg/L and required monitoring for public water sources.</p>	

DBCP OCCURRENCE	
Anthropogenic Sources	Prior to 1979, DBCP was primarily used as a soil fumigant for the control of nematodes in over 40 different crops in the United States. Today very small quantities of DBCP are manufactured only for the purpose of chemical synthesis of other compounds.
Natural Sources	DBCP is a manufactured chemical that does not occur naturally in the environment.
History of Occurrence	<p>Data collected on workers involved in the manufacture and formulation of DBCP has shown that DBCP can cause sterility at very low levels of exposure. Agricultural application of DBCP was banned in the United States in 1979, with the exception of use in the Hawaiian pineapple industry. Use in the pineapple farming industry was banned in 1985. Today, DBCP is only used as a chemical intermediary in the manufacture of synthetic compounds. The total volume of DBCP manufactured for this purpose is believed to be very small.</p> <p>In California, DBCP was used extensively prior to 1979. DBCP was one of the most useful and simple to use nematicides. In 1977, 831,000 pounds of DBCP were used in California, primarily on grapes and tomatoes. DBCP has been detected in public groundwater sources in California, with the majority of occurrences in Fresno, San Bernardino, Stanislaus and Tulare counties.</p>
Contaminant Transport Characteristics	DBCP dissolves in water, and may occur as a dense non-aqueous phase liquid. Its density is greater than the water; free phase DBCP may sink to the bottom of an aquifer where it can persist for long periods of time. The half-life of DBCP in an aquifer with a temperature of 15° C is estimated at 141 years. In the atmosphere DBCP is easily broken down by sunlight. DBCP is not likely to accumulate in aquatic life.

REMEDATION & TREATMENT TECHNOLOGIES

The removal of DBCP from water can be accomplished through different methodologies, including air-stripping and filtration using granulated activated carbon. DBCP can also be removed using hydrogen peroxide combined with a catalyst (Fenton's Reagent). Ozone is a strong oxidant that can react with and oxidize DBCP to carbon dioxide and water.

Zero-valent iron (FeO) is frequently used *in situ* to remove DBCP in passive remediation systems. In the simplest application of this technology, a permeable reactive barrier or iron wall is installed by digging a trench perpendicular to the direction of groundwater flow and back-filling it with iron. Water that passes through the zero-valent iron barrier is stripped of DBCP.

The US EPA approved treatment method for the removal of DBCP in drinking water is to use granulated activated carbon with packed tower aeration.

HEALTH EFFECT INFORMATION


Ingestion of DBCP results in gastrointestinal distress and pulmonary edema. The likelihood of exposure to DBCP through food sources is extremely low since DBCP rapidly volatilizes when exposed to air and sunlight. Additional exposure pathways are through inhalation and direct contact.

Acute inhalation exposure to DBCP in humans results in moderate depression of the central nervous system, kidney and liver damage, and pulmonary congestion. Dermal exposure may irritate the skin and eyes in humans and animals. Even low exposure to DBCP by humans may cause sterility in men or other male reproductive effects, such as decreased or no sperm counts. There is some evidence that DBCP may have the potential to cause cancer with lifetime exposure at levels above the MCL.

KEY REFERENCES


1. U.S. Environmental Protection Agency. 2007. Technology Transfer Network. DBCP. <http://www.epa.gov/ttnatw01/hlthef/dibromo-.html#ref1>
2. U.S. Environmental Protection Agency. 2006. Groundwater and Drinking Water. Consumer Fact Sheet on: Dibromochloropropane. http://www.epa.gov/ogwdw/contaminants/dw_contamfs/dibromoc.html
3. Water Standards and Criteria. U.S. National Drinking Water Standards and Health Criteria. 2007. <http://www.cdpr.ca.gov/docs/emon/pubs/ehapreps.htm>
4. U.S. Environmental Protection Agency. 2007. Analytical Methodology. <http://www.epa.gov/ogwdw000/methods/methods.html>
<http://www.epa.gov/microbes/methmans.html>.
5. U.S. Environmental Protection Agency. 2006. Technical Factsheet on: Dibromochloropropane (DBCP). <http://www.epa.gov/OGWDW/dwh/t-soc/dbcp.html>
6. U.S. Environmental Protection Agency. 1995. Method 504.1. Specific publications EPA/600/R-95-131. Determination of Organic Compounds in drinking water (EDB, DBCP and 1,2,3 trichloropropane) by micro-extraction and GC.
7. Marshack, J.B. 2008. California Environmental Protection Agency/ Regional Water Quality Control Board, Central Valley Region. A Compilation of Water Quality Goals.
8. Montgomery, J.H. 1993. Agrochemicals Desk References. Environmental Data. Lewis Publishers, pg. 139-140.
9. PRIMA Environmental. 2007. Innovative and Emerging Remediation Technologies. <http://www.primaenvironmental.com/emerging.html>
10. U.S. Department of Labor. 2007. Medical Surveillance guidelines for DBCP-1910.1044. http://www.osha.gov/pls/oshaweb/owadisp.show_document?p_id=10064&p_table=STANDARDS
11. ATSDR. 1992. Agency for Toxic Substances and Disease Registry. Toxicological Profile for 1,2-dibromo-3-chloropropane. U.S. Department of Health and Human Services, Public Health Service, ATSDR. Publication TP-91/12.
12. Office of Environmental Health Hazard Assessment California Environmental Protection Agency. 1999. Public Health Goal for 1,2-Dibromo 3-chloropropane (DBCP) in Drinking Water.

FOR MORE INFORMATION, CONTACT: John Borkovich, SWRCB (916) 341-5779.



Active and Standby California Department of Public Health (CDPH) Regulated Public Water Wells with at Least One Detection of DBCP > 0.2 µg/L (MCL). (7,689 wells sampled, 1027 wells reported detections, 364 wells above MCL)

Source: June 2010 well query of CDPH data using GeoTracker GAMA.



Abandoned, Destroyed and Inactive California Department of Public Health (CDPH) Regulated Public Water Wells with at Least One Detection of DBCP > 0.2 µg/L (MCL). (2326 wells sampled, 422 wells reported detections, 211 wells above MCL)

Source: June 2010 well query of CDPH data using GeoTracker GAMA.